

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
Carbon Treatment System						
GC0218-BELPSD-PT	2/14/2018	0.34		0.013	Prior to Treatment Sample	
GC0218-BELPSD-BED2N-Lead	2/14/2018	0.11		0.010	After Carbon Bed Sample	
GC0218-BELPSD-BED1N-Lag	2/14/2018	<0.010		0.010	After Carbon Bed Sample	
GC0218-BELPSD-BED1N-Lag-D	2/14/2018	<0.010		0.010	After Carbon Bed Sample-duplicate	
GC0218-BELPSD-BED2S-Lead	2/14/2018	0.10 J		0.010	After Carbon Bed Sample	Analyte present. Reported value may not be accurate or precise.
GC0218-BELPSD-BED1S-Lag	2/14/2018	0.010		0.010	After Carbon Bed Sample	
GC0118-BELPSD-PT	1/24/2018	0.36		0.013	Prior to Treatment Sample	
GC0118-BELPSD-BED2N-Lead	1/24/2018	0.11		0.010	After Carbon Bed Sample	
GC0118-BELPSD-BED1N-Lag-D	1/24/2018	<0.010		0.010	After Carbon Bed Sample-duplicate	
GC0118-BELPSD-BED1N-Lag	1/24/2018	<0.010		0.010	After Carbon Bed Sample	
GC0118-BELPSD-BED2S-Lead	1/24/2018	0.096		0.010	After Carbon Bed Sample	
GC0118-BELPSD-BED1S-Lag	1/24/2018	<0.010		0.010	After Carbon Bed Sample	
GC1217-BELPSD-PT	12/21/2017	0.36		0.014	Prior to Treatment Sample	
GC1217-BELPSD-BED2N-Lead	12/21/2017	0.064		0.010	After Carbon Bed Sample	
GC1217-BELPSD-BED1N-Lag	12/21/2017	<0.010		0.010	After Carbon Bed Sample	
GC1217-BELPSD-BED1N-Lag-D	12/21/2017	<0.010		0.010	After Carbon Bed Sample-duplicate	
GC1217-BELPSD-BED2S-Lead	12/21/2017	0.060		0.010	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC1217-BELPSD-BED1S-Lag	12/21/2017	<0.010		0.010	After Carbon Bed Sample	
GC1117-BELPSD-PT	11/29/2017	0.38		0.014	Prior to Treatment Sample	
GC1117-BELPSD-BED2N-Lead	11/29/2017	0.043		0.010	After Carbon Bed Sample	Carbon Changeout 11/28/2017
GC1117-BELPSD-BED1N-Lag-D	11/29/2017	<0.010		0.010	After Carbon Bed Sample-duplicate	Carbon Changeout 11/28/2017
GC1117-BELPSD-BED1N-Lag	11/29/2017	<0.010		0.010	After Carbon Bed Sample	Carbon Changeout 11/28/2017
GC1117-BELPSD-BED2S-Lead	11/29/2017	0.034		0.010	After Carbon Bed Sample	Carbon Changeout 11/28/2017
GC1117-BELPSD-BED1S-Lag	11/29/2017	<0.010		0.010	After Carbon Bed Sample	Carbon Changeout 11/28/2017
GC1017-BELPSD-PT	10/19/2017	0.32		0.014	Prior to Treatment Sample	
GC1017-BELPSD-BED1N-Lead	10/19/2017	0.26 J		0.014	After Carbon Bed Sample	Analyte present. Reported value may not be accurate or precise.
GC1017-BELPSD-BED1N-Lead-D	10/19/2017	0.21 J		0.013	After Carbon Bed Sample-duplicate	Analyte present. Reported value may not be accurate or precise.
GC1017-BELPSD-BED2N-Lag	10/19/2017	0.014		0.010	After Carbon Bed Sample	
GC1017-BELPSD-BED1S-Lead	10/19/2017	0.23		0.014	After Carbon Bed Sample	
GC1017-BELPSD-BED2S-Lag	10/19/2017	0.016		0.010	After Carbon Bed Sample	
GC0917-BELPSD-PT	9/19/2017	0.31		0.011	Prior to Treatment Sample	
GC0917-BELPSD-BED1N-Lead-D	9/19/2017	0.20		0.011	After Carbon Bed Sample-duplicate	
GC0917-BELPSD-BED1N-Lead	9/19/2017	0.18 J		0.011	After Carbon Bed Sample	Analyte present. Reported value may not be accurate or precise.

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0917-BELPSD-BED2N-Lag	9/19/2017	<0.010		0.010	After Carbon Bed Sample	
GC0917-BELPSD-BED1S-Lead	9/19/2017	0.22		0.011	After Carbon Bed Sample	
GC0917-BELPSD-BED2S-Lag	9/19/2017	<0.010		0.010	After Carbon Bed Sample	
GC0817-BELPSD-PT	8/24/2017	0.32		0.014	Prior to Treatment Sample	
GC0817-BELPSD-BED1N-Lead-D	8/24/2017	0.17		0.010	After Carbon Bed Sample-duplicate	
GC0817-BELPSD-BED1N-Lead	8/24/2017	0.19		0.010	After Carbon Bed Sample	
GC0817-BELPSD-BED2N-Lag	8/24/2017	0.014		0.010	After Carbon Bed Sample	
GC0817-BELPSD-BED1S-Lead	8/24/2017	0.22		0.014	After Carbon Bed Sample	
GC0817-BELPSD-BED2S-Lag	8/24/2017	0.011		0.010	After Carbon Bed Sample	
GC0717-BELPSD-PT	7/19/2017	0.34		0.014	Prior to Treatment Sample	
GC0717-BELPSD-BED1N-Lead-D	7/19/2017	0.21		0.010	After Carbon Bed Sample-duplicate	
GC0717-BELPSD-BED1N-Lead	7/19/2017	0.21		0.011	After Carbon Bed Sample	
GC0717-BELPSD-BED2N-Lag	7/19/2017	<0.010		0.010	After Carbon Bed Sample	
GC0717-BELPSD-BED1S-Lead	7/19/2017	0.23		0.010	After Carbon Bed Sample	
GC0717-BELPSD-BED2S-Lag	7/19/2017	<0.010		0.010	After Carbon Bed Sample	
GC0617-BELPSD-PT	6/20/2017	0.31		0.013	Prior to Treatment Sample	
GC0617-BELPSD-BED1N-Lead	6/20/2017	0.17		0.013	After Carbon Bed Sample	
GC0617-BELPSD-BED1N-Lead-D	6/20/2017	0.17		0.010	After Carbon Bed Sample-duplicate	
GC0617-BELPSD-BED2N-Lag	6/20/2017	<0.010		0.010	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0617-BELPSD-BED1S-Lead	6/20/2017	0.19		0.010	After Carbon Bed Sample	
GC0617-BELPSD-BED2S-Lag	6/20/2017	<0.010		0.010	After Carbon Bed Sample	
GC0517-BELPSD-PT	5/25/2017	0.33		0.013	Prior to Treatment Sample	
GC0517-BELPSD-BED1N-Lead	5/25/2017	0.17		0.013	After Carbon Bed Sample	
GC0517-BELPSD-BED1N-Lead-D	5/25/2017	0.16		0.014	After Carbon Bed Sample-duplicate	
GC0517-BELPSD-BED2N-Lag	5/25/2017	<0.010		0.010	After Carbon Bed Sample	
GC0517-BELPSD-BED1S-Lead	5/25/2017	0.19		0.013	After Carbon Bed Sample	
GC0517-BELPSD-BED2S-Lag	5/25/2017	<0.010		0.010	After Carbon Bed Sample	
GC0417-BELPSD-PT	4/21/2017	0.33		0.043	Prior to Treatment Sample	
GC0417-BELPSD-BED1N-Lead	4/21/2017	0.12		0.010	After Carbon Bed Sample	
GC0417-BELPSD-BED1N-Lead-D	4/21/2017	0.12		0.010	After Carbon Bed Sample-duplicate	
GC0417-BELPSD-BED2N-Lag	4/21/2017	<0.010		0.010	After Carbon Bed Sample	
GC0417-BELPSD-BED1S-Lead	4/21/2017	0.16		0.017	After Carbon Bed Sample	
GC0417-BELPSD-BED2S-Lag	4/21/2017	<0.010		0.010	After Carbon Bed Sample	
GC0317-BELPSD-PT	3/23/2017	0.29		0.048	Prior to Treatment Sample	
GC0317-BELPSD-BED1N-Lead	3/23/2017	0.11 J		0.018	After Carbon Bed Sample	Analyte present. Reported value may not be accurate or precise.
GC0317-BELPSD-BED1N-Lead-D	3/23/2017	0.10		0.010	After Carbon Bed Sample-duplicate	
GC0317-BELPSD-BED2N-Lag	3/23/2017	<0.010		0.010	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0317-BELPSD-BED1S-Lead	3/23/2017	0.13		0.010	After Carbon Bed Sample	
GC0317-BELPSD-BED2S-Lag	3/23/2017	<0.010		0.010	After Carbon Bed Sample	
GC0217-BELPSD-PT	2/24/2017	0.32		0.047	Prior to Treatment Sample	
GC0217-BELPSD-BED1N-Lead-D	2/24/2017	0.094		0.010	After Carbon Bed Sample-duplicate	
GC0217-BELPSD-BED1N-Lead	2/24/2017	0.093		0.010	After Carbon Bed Sample	
GC0217-BELPSD-BED2N-Lag	2/24/2017	<0.010		0.010	After Carbon Bed Sample	
GC0217-BELPSD-BED1S-Lead	2/24/2017	0.12		0.010	After Carbon Bed Sample	
GC0217-BELPSD-BED2S-Lag	2/24/2017	<0.010		0.010	After Carbon Bed Sample	
GC0117-BELPSD-PT	1/25/2017	0.28		0.042	Prior to Treatment Sample	
GC0117-BELPSD-BED1N-Lead	1/25/2017	0.071		0.010	After Carbon Bed Sample	
GC0117-BELPSD-BED1N-Lead-D	1/25/2017	0.070		0.010	After Carbon Bed Sample-duplicate	
GC0117-BELPSD-BED2N-Lag	1/25/2017	<0.010		0.010	After Carbon Bed Sample	
GC0117-BELPSD-BED1S-Lead	1/25/2017	0.10		0.010	After Carbon Bed Sample	
GC0117-BELPSD-BED2S-Lag	1/25/2017	<0.010		0.010	After Carbon Bed Sample	
GC1216-BELPSD-PT	12/22/2016	0.35		0.047	Prior to Treatment Sample	
GC1216-BELPSD-BED1N-Lead-D	12/22/2016	0.054		0.010	After Carbon Bed Sample-duplicate	
GC1216-BELPSD-BED1N-Lead	12/22/2016	0.053		0.010	After Carbon Bed Sample	
GC1216-BELPSD-BED2N-Lag	12/22/2016	<0.010		0.010	After Carbon Bed Sample	
GC1216-BELPSD-BED1S-Lead	12/22/2016	0.091		0.010	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC1216-BELPSD-BED2S-Lag	12/22/2016	<0.010		0.010	After Carbon Bed Sample	
GC1116-BELPSD-PT	11/18/2016	0.35		0.049	Prior to Treatment Sample	Carbon Changeout on 11/17/2016
GC1116-BELPSD-BED1N-LEAD	11/18/2016	0.022		0.010	After Carbon Bed Sample	Carbon Changeout on 11/17/2016
GC1116-BELPSD-BED1N-LEAD-D	11/18/2016	0.021		0.010	After Carbon Bed Sample-duplicate	Carbon Changeout on 11/17/2016
GC1116-BELPSD-BED2N-LAG	11/18/2016	<0.010		0.010	After Carbon Bed Sample	Carbon Changeout on 11/17/2016
GC1116-BELPSD-BED1S-LEAD	11/18/2016	0.064		0.010	After Carbon Bed Sample	Carbon Changeout on 11/17/2016
GC1116-BELPSD-BED2S-LAG	11/18/2016	<0.010		0.010	After Carbon Bed Sample	Carbon Changeout on 11/17/2016
GC1016-BELPSD-PT	10/18/2016	0.35		0.042	Prior to Treatment Sample	
GC1016-BELPSD-BED2N-Lead	10/18/2016	0.25		0.041	After Carbon Bed Sample	
GC1016-BELPSD-BED1N-Lag-D	10/18/2016	0.014		0.010	After Carbon Bed Sample-duplicate	
GC1016-BELPSD-BED1N-Lag	10/18/2016	0.014		0.010	After Carbon Bed Sample	
GC1016-BELPSD-BED2S-Lead	10/18/2016	0.22		0.041	After Carbon Bed Sample	
GC1016-BELPSD-BED1S-Lag	10/18/2016	0.046		0.010	After Carbon Bed Sample	
GC916-BELPSD-PT	9/20/2016	0.28		0.0050	Prior to Treatment Sample	
GC916-BELPSD-BED2N-Lead	9/20/2016	0.17		0.0050	After Carbon Bed Sample	
GC916-BELPSD-BED1N-Lag	9/20/2016	<0.0050		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC916-BELPSD-BED1N-Lag-D	9/20/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC916-BELPSD-BED2S-Lead	9/20/2016	0.17		0.0050	After Carbon Bed Sample	
GC916-BELPSD-BED1S-Lag	9/20/2016	0.018		0.0050	After Carbon Bed Sample	
GC816-BELPSD-PT	8/23/2016	0.27		0.0050	Prior to Treatment Sample	
GC816-BELPSD-BED2N-Lead	8/23/2016	0.16		0.0050	After Carbon Bed Sample	
GC816-BELPSD-BED1N-Lag-D	8/23/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC816-BELPSD-BED1N-Lag	8/23/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC816-BELPSD-BED2S-Lead	8/23/2016	0.15		0.0050	After Carbon Bed Sample	
GC816-BELPSD-BED1S-Lag	8/23/2016	0.0094		0.0050	After Carbon Bed Sample	
GC716-BELPSD-PT	7/21/2016	0.25		0.0050	Prior to Treatment Sample	
GC716-BELPSD-BED2N-Lead	7/21/2016	0.12		0.0050	After Carbon Bed Sample	
GC716-BELPSD-BED1N-Lag-D	7/21/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC716-BELPSD-BED1N-Lag	7/21/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC716-BELPSD-BED2S-Lead	7/21/2016	0.12		0.0050	After Carbon Bed Sample	
GC716-BELPSD-BED1S-Lag	7/21/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC616-BELPSD-PT	6/15/2016	0.23		0.0050	Prior to Treatment Sample	
GC616-BELPSD-BED2N-Lead	6/15/2016	0.099		0.0050	After Carbon Bed Sample	
GC616-BELPSD-BED1N-Lag	6/15/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC616-BELPSD-BED1N-Lag-D	6/15/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC616-BELPSD-BED2S-Lead	6/15/2016	0.099		0.0050	After Carbon Bed Sample	
GC616-BELPSD-BED1S-Lag	6/15/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC516-BELPSD-PT	5/17/2016	0.24		0.0050	Prior to Treatment Sample	
GC516-BELPSD-BED2N-Lead	5/17/2016	0.093		0.0050	After Carbon Bed Sample	
GC516-BELPSD-BED1N-Lag-D	5/17/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC516-BELPSD-BED1N-Lag	5/17/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC516-BELPSD-BED2S-Lead	5/17/2016	0.094		0.0050	After Carbon Bed Sample	
GC516-BELPSD-BED1S-Lag	5/17/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC416-BELPSD-PT	4/19/2016	0.28		0.0050	Prior to Treatment Sample	
GC416-BELPSD-BED2N-Lead	4/19/2016	0.091		0.0050	After Carbon Bed Sample	
GC416-BELPSD-BED1N-Lag	4/19/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC416-BELPSD-BED1N-Lag-D	4/19/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC416-BELPSD-BED2S-Lead	4/19/2016	0.092		0.0050	After Carbon Bed Sample	
GC416-BELPSD-BED1S-Lag	4/19/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC316-BELPSD-PT	3/18/2016	0.25		0.0050	Prior to Treatment Sample	
GC316-BELPSD-BED2N-Lead	3/18/2016	0.062		0.0050	After Carbon Bed Sample	
GC316-BELPSD-BED1N-Lag-D	3/18/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC316-BELPSD-BED1N-Lag	3/18/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC316-BELPSD-BED2S-Lead	3/18/2016	0.062		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC316-BELPSD-BED1S-Lag	3/18/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC216-BELPSD-PT	2/19/2016	0.27		0.0050	Prior to Treatment Sample	
GC216-BELPSD-BED2N-Lead	2/19/2016	0.045		0.0050	After Carbon Bed Sample	
GC216-BELPSD-BED1N-Lag	2/19/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC216-BELPSD-BED1N-Lag-D	2/19/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC216-BELPSD-BED2S-Lead	2/19/2016	0.055		0.0050	After Carbon Bed Sample	
GC216-BELPSD-BED1S-Lag	2/19/2016	<0.0050		0.0050	After Carbon Bed Sample	
GC116-BELPSD-PT	1/26/2016	0.28		0.0050	Prior to Treatment Sample	Carbon Changeout 01/21/2016
GC116-BELPSD-BED2N-Lead	1/26/2016	0.026		0.0050	After Carbon Bed Sample	Carbon Changeout 01/21/2016
GC116-BELPSD-BED1N-Lag-D	1/26/2016	<0.0050		0.0050	After Carbon Bed Sample-duplicate	Carbon Changeout 01/21/2016
GC116-BELPSD-BED1N-Lag	1/26/2016	<0.0050		0.0050	After Carbon Bed Sample	Carbon Changeout 01/21/2016
GC116-BELPSD-BED2S-Lead	1/26/2016	0.033		0.0050	After Carbon Bed Sample	Carbon Changeout 01/21/2016
GC116-BELPSD-BED1S-Lag	1/26/2016	<0.0050		0.0050	After Carbon Bed Sample	Carbon Changeout 01/21/2016
GC1215-BELPSD-PT	12/18/2015	0.29		0.0050	Prior to Treatment Sample	
GC1215-BELPSD-BED1N-Lead-D	12/18/2015	0.17		0.0050	After Carbon Bed Sample-duplicate	
GC1215-BELPSD-BED1N-Lead	12/18/2015	0.18		0.0050	After Carbon Bed Sample	
GC1215-BELPSD-BED2N-Lag	12/18/2015	0.026		0.0050	After Carbon Bed Sample	
GC1215-BELPSD-BED1S-Lead	12/18/2015	0.22		0.0050	After Carbon Bed Sample	
GC1215-BELPSD-BED2S-Lag	12/18/2015	0.015		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC1115-BELPSD-PT	11/18/2015	0.30		0.0050	Prior to Treatment Sample	
GC1115-BELPSD-BED1N-Lead	11/18/2015	0.17		0.0050	After Carbon Bed Sample	
GC1115-BELPSD-BED1N-Lead-D	11/18/2015	0.17		0.0050	After Carbon Bed Sample-duplicate	
GC1115-BELPSD-BED2N-Lag	11/18/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC1115-BELPSD-BED1S-Lead	11/18/2015	0.16		0.0050	After Carbon Bed Sample	
GC1115-BELPSD-BED2S-Lag	11/18/2015	0.0054		0.0050	After Carbon Bed Sample	
GC1015-BELPSD-PT	10/20/2015	0.30		0.0050	Prior to Treatment Sample	
GC1015-BELPSD-BED1N-Lead	10/20/2015	0.16		0.0050	After Carbon Bed Sample	
GC1015-BELPSD-BED1N-Lead-D	10/20/2015	0.15		0.0050	After Carbon Bed Sample-duplicate	
GC1015-BELPSD-BED2N-Lag	10/20/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC1015-BELPSD-BED1S-Lead	10/20/2015	0.16		0.0050	After Carbon Bed Sample	
GC1015-BELPSD-BED2S-Lag	10/20/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0915-BELPSD-PT	9/22/2015	0.24		0.0050	Prior to Treatment Sample	
GC0915-BELPSD-BED1N-Lead	9/22/2015	0.12		0.0050	After Carbon Bed Sample	
GC0915-BELPSD-BED1N-Lead-D	9/22/2015	0.13		0.0050	After Carbon Bed Sample-duplicate	
GC0915-BELPSD-BED2N-Lag	9/22/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0915-BELPSD-BED1S-Lead	9/22/2015	0.12		0.0050	After Carbon Bed Sample	
GC0915-BELPSD-BED2S-Lag	9/22/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0815-BELPSD-PT	8/21/2015	0.23		0.0050	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0815-BELPSD-BED1N-Lead	8/21/2015	0.10		0.0050	After Carbon Bed Sample	
GC0815-BELPSD-BED1N-Lead-D	8/21/2015	0.11		0.0050	After Carbon Bed Sample-duplicate	
GC0815-BELPSD-BED2N-Lag	8/21/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0815-BELPSD-BED1S-Lead	8/21/2015	0.11		0.0050	After Carbon Bed Sample	
GC0815-BELPSD-BED2S-Lag	8/21/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0715-BELPSD-PT	7/21/2015	0.25		0.0050	Prior to Treatment Sample	
GC0715-BELPSD-BED1N-Lead-D	7/21/2015	0.11		0.0050	After Carbon Bed Sample-duplicate	
GC0715-BELPSD-BED1N-Lead	7/21/2015	0.096		0.0050	After Carbon Bed Sample	
GC0715-BELPSD-BED2N-Lag	7/21/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0715-BELPSD-BED1S-Lead	7/21/2015	0.10		0.0050	After Carbon Bed Sample	
GC0715-BELPSD-BED2S-Lag	7/21/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0615-BELPSD-PT	6/16/2015	0.26		0.0050	Prior to Treatment Sample	
GC0615-BELPSD-BED1N-Lead-D	6/16/2015	0.094		0.0050	After Carbon Bed Sample-duplicate	
GC0615-BELPSD-BED1N-Lead	6/16/2015	0.094		0.0050	After Carbon Bed Sample	
GC0615-BELPSD-BED2N-Lag	6/16/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0615-BELPSD-BED1S-Lead	6/16/2015	0.091		0.0050	After Carbon Bed Sample	
GC0615-BELPSD-BED2S-Lag	6/16/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0515-BELPSD-PT	5/20/2015	0.25		0.0050	Prior to Treatment Sample	
GC0515-BELPSD-BED1N-Lead	5/20/2015	0.078		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0515-BELPSD-BED1N-Lead-D	5/20/2015	0.072		0.0050	After Carbon Bed Sample-duplicate	
GC0515-BELPSD-BED2N-Lag	5/20/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0515-BELPSD-BED1S-Lead	5/20/2015	0.077		0.0050	After Carbon Bed Sample	
GC0515-BELPSD-BED2S-Lag	5/20/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0415-BELPSD-PT	4/20/2015	0.28		0.0050	Prior to Treatment Sample	
GC0415-BELPSD-BED1N-Lead-D	4/20/2015	0.063		0.0050	After Carbon Bed Sample-duplicate	
GC0415-BELPSD-BED1N-Lead	4/20/2015	0.057		0.0050	After Carbon Bed Sample	
GC0415-BELPSD-BED2N-Lag	4/20/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0415-BELPSD-BED1S-Lead	4/20/2015	0.062		0.0050	After Carbon Bed Sample	
GC0415-BELPSD-BED2S-Lag	4/20/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0315-BELPSD-PT	3/19/2015	0.25		0.0050	Prior to Treatment Sample	
GC0315-BELPSD-BED1N-Lead	3/19/2015	0.046		0.0050	After Carbon Bed Sample	
GC0315-BELPSD-BED1N-Lead-D	3/19/2015	0.050		0.0050	After Carbon Bed Sample-duplicate	
GC0315-BELPSD-BED2N-Lag	3/19/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0315-BELPSD-BED1S-Lead	3/19/2015	0.043		0.0050	After Carbon Bed Sample	
GC0315-BELPSD-BED2S-Lag	3/19/2015	<0.0050		0.0050	After Carbon Bed Sample	
GC0215-BELPSD-PT	2/20/2015	0.28		0.0050	Prior to Treatment Sample	Carbon Changeout 2/18/2015
GC0215-BELPSD-BED1N-Lead	2/20/2015	0.042		0.0050	After Carbon Bed Sample	Carbon Changeout 2/18/2015
GC0215-BELPSD-BED1N-Lead-D	2/20/2015	0.042		0.0050	After Carbon Bed Sample-duplicate	Carbon Changeout 2/18/2015

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0215-BELPSD-BED2N-Lag	2/20/2015	<0.0050		0.0050	After Carbon Bed Sample	Carbon Changeout 2/18/2015
GC0215-BELPSD-BED1S-Lead	2/20/2015	0.038		0.0050	After Carbon Bed Sample	Carbon Changeout 2/18/2015
GC0215-BELPSD-BED2S-Lag	2/20/2015	<0.0050		0.0050	After Carbon Bed Sample	Carbon Changeout 2/18/2015
GC0115-BELPSD-PT	1/21/2015	0.29		0.0050	Prior to Treatment Sample	
GC0115-BELPSD-BED2N-Lead	1/21/2015	0.19		0.0050	After Carbon Bed Sample	
GC0115-BELPSD-BED1N-Lag	1/21/2015	0.025		0.0050	After Carbon Bed Sample	
GC0115-BELPSD-BED1N-Lag-D	1/21/2015	0.025		0.0050	After Carbon Bed Sample-duplicate	
GC0115-BELPSD-BED2S-Lead	1/21/2015	0.18		0.0050	After Carbon Bed Sample	
GC0115-BELPSD-BED1S-Lag	1/21/2015	0.022		0.0050	After Carbon Bed Sample	
GC1214-BELPSD-PT	12/18/2014	0.26		0.0050	Prior to Treatment Sample	
GC1214-BELPSD-BED2N-Lead	12/18/2014	0.17		0.0050	After Carbon Bed Sample	
GC1214-BELPSD-BED1N-Lag-D	12/18/2014	0.0097		0.0050	After Carbon Bed Sample-duplicate	
GC1214-BELPSD-BED1N-Lag	12/18/2014	0.011		0.0050	After Carbon Bed Sample	
GC1214-BELPSD-BED2S-Lead	12/18/2014	0.15		0.0050	After Carbon Bed Sample	
GC1214-BELPSD-BED1S-Lag	12/18/2014	0.0085		0.0050	After Carbon Bed Sample	
GC1114-BELPSD-PT	11/19/2014	0.17		0.0050	Prior to Treatment Sample	Does not meet operational condition of PT>Lead>Lag results
GC1114-BELPSD-BED2N-Lead	11/19/2014	0.15		0.0050	After Carbon Bed Sample	
GC1114-BELPSD-BED1N-Lag-D	11/19/2014	0.0085		0.0050	After Carbon Bed Sample-duplicate	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC1114-BELPSD-BED1N-Lag	11/19/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC1114-BELPSD-BED2S-Lead	11/19/2014	0.29		0.0050	After Carbon Bed Sample	Does not meet operational condition of PT>Lead>Lag results
GC1114-BELPSD-BED1S-Lag	11/19/2014	0.0083		0.0050	After Carbon Bed Sample	
GC1014-BELPSD-PT	10/21/2014	0.28		0.0050	Prior to Treatment Sample	
GC1014-BELPSD-BED2N-Lead	10/21/2014	0.15		0.0050	After Carbon Bed Sample	
GC1014-BELPSD-BED1N-Lag-D	10/21/2014	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC1014-BELPSD-BED1N-Lag	10/21/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC1014-BELPSD-BED2S-Lead	10/21/2014	0.15		0.0050	After Carbon Bed Sample	
GC1014-BELPSD-BED1S-Lag	10/21/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC914-BELPSD-PT	9/24/2014	0.26		0.0050	Prior to Treatment Sample	
GC914-BELPSD-BED2N-Lead	9/24/2014	0.13		0.0050	After Carbon Bed Sample	
GC914-BELPSD-BED1N-Lag	9/24/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC914-BELPSD-BED1N-Lag-D	9/24/2014	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC914-BELPSD-BED2S-Lead	9/24/2014	0.12		0.0050	After Carbon Bed Sample	
GC914-BELPSD-BED1S-Lag	9/24/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC814-BELPSD-PT	8/21/2014	0.25		0.0050	Prior to Treatment Sample	
GC814-BELPSD-BED2N-Lead	8/21/2014	0.10		0.0050	After Carbon Bed Sample	
GC814-BELPSD-BED1N-Lag	8/21/2014	<0.0050		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC814-BELPSD-BED1N-Lag-D	8/21/2014	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC814-BELPSD-BED2S-Lead	8/21/2014	0.094		0.0050	After Carbon Bed Sample	
GC814-BELPSD-BED1S-Lag	8/21/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC714-BELPSD-PT	7/22/2014	0.28		0.0050	Prior to Treatment Sample	
GC714-BELPSD-BED2N-Lead	7/22/2014	0.099		0.0050	After Carbon Bed Sample	
GC714-BELPSD-BED1N-Lag	7/22/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC714-BELPSD-BED1N-Lag-D	7/22/2014	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC714-BELPSD-BED2S-Lead	7/22/2014	0.084		0.0050	After Carbon Bed Sample	
GC714-BELPSD-BED1S-Lag	7/22/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC614-BELPSD-PT	6/17/2014	0.24		0.0050	Prior to Treatment Sample	
GC614-BELPSD-BED2N-Lead	6/17/2014	0.081		0.0050	After Carbon Bed Sample	
GC614-BELPSD-BED1N-Lag-D	6/17/2014	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC614-BELPSD-BED1N-Lag	6/17/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC614-BELPSD-BED2S-Lead	6/17/2014	0.064		0.0050	After Carbon Bed Sample	
GC614-BELPSD-BED1S-Lag	6/17/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC514-BELPSD-PT	5/21/2014	0.28		0.0050	Prior to Treatment Sample	
GC514-BELPSD-BED2N-Lead	5/21/2014	0.065		0.0050	After Carbon Bed Sample	
GC514-BELPSD-BED1N-Lag-D	5/21/2014	<0.0050		0.0050	After Carbon Bed Sample-duplicate	
GC514-BELPSD-BED1N-Lag	5/21/2014	<0.0050		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC514-BELPSD-BED2S-Lead	5/21/2014	0.053		0.0050	After Carbon Bed Sample	
GC514-BELPSD-BED1S-Lag	5/21/2014	<0.0050		0.0050	After Carbon Bed Sample	
GC414-BELPSD-PT	4/22/2014	0.29		0.0050	Prior to Treatment Sample	Carbon Changeout 4/10/2014
GC414-BELPSD-BED2N-Lead	4/22/2014	0.050		0.0050	After Carbon Bed Sample	Carbon Changeout 4/10/2014
GC414-BELPSD-BED1N-Lag-D	4/22/2014	<0.0050		0.0050	After Carbon Bed Sample-duplicate	Carbon Changeout 4/10/2014
GC414-BELPSD-BED1N-Lag	4/22/2014	<0.0050		0.0050	After Carbon Bed Sample	Carbon Changeout 4/10/2014
GC414-BELPSD-BED2S-Lead	4/22/2014	0.041		0.0050	After Carbon Bed Sample	Carbon Changeout 4/10/2014
GC414-BELPSD-BED1S-Lag	4/22/2014	<0.0050		0.0050	After Carbon Bed Sample	Carbon Changeout 4/10/2014
GC314-BELPSD-PT	3/21/2014	0.33		0.0050	Prior to Treatment Sample	
GC314-BELPSD-BED1N-Lead-D	3/21/2014	0.095		0.0050	After Carbon Bed Sample-duplicate	
GC314-BELPSD-BED1N-Lead	3/21/2014	0.12		0.0050	After Carbon Bed Sample	
GC314-BELPSD-BED2N-Lag	3/21/2014	0.014		0.0050	After Carbon Bed Sample	
GC314-BELPSD-BED1S-Lead	3/21/2014	0.10		0.0050	After Carbon Bed Sample	
GC314-BELPSD-BED2S-Lag	3/21/2014	0.013		0.0050	After Carbon Bed Sample	
GC214-BELPSD-PT	2/19/2014	0.22		0.0050	Prior to Treatment Sample	
GC214-BELPSD-BED1N-Lead	2/19/2014	0.12		0.0050	After Carbon Bed Sample	
GC214-BELPSD-BED1N-Lead-D	2/19/2014	0.098		0.0050	After Carbon Bed Sample-duplicate	
GC214-BELPSD-BED2N-Lag	2/19/2014	0.0097		0.0050	After Carbon Bed Sample	
GC214-BELPSD-BED1S-Lead	2/19/2014	0.11		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC214-BELPSD-BED2S-Lag	2/19/2014	0.013		0.0050	After Carbon Bed Sample	
GC114-BELPSD-PT	1/22/2014	0.41		0.0050	Prior to Treatment Sample	
GC114-BELPSD-BED1N-Lead	1/22/2014	0.13		0.0050	After Carbon Bed Sample	
GC114-BELPSD-BED1N-Lead-D	1/22/2014	0.13		0.0050	After Carbon Bed Sample-duplicate	
GC114-BELPSD-BED2N-Lag	1/22/2014	0.0071		0.0050	After Carbon Bed Sample	
GC114-BELPSD-BED1S-Lead	1/22/2014	0.11		0.0050	After Carbon Bed Sample	
GC114-BELPSD-BED2S-Lag	1/22/2014	0.0058		0.0050	After Carbon Bed Sample	
GC1213-BELPSD-PT	12/20/2013	0.41		0.0050	Prior to Treatment Sample	
GC1213-BELPSD-BED1N-Lead-D	12/20/2013	0.066 J		0.0050	After Carbon Bed Sample-duplicate	Analyte present. Reported value may not be accurate or precise.
GC1213-BELPSD-BED1N-Lead	12/20/2013	0.086 J		0.0050	After Carbon Bed Sample	
GC1213-BELPSD-BED2N-Lag	12/20/2013	<0.0050		0.0050	After Carbon Bed Sample	
GC1213-BELPSD-BED1S-Lead	12/20/2013	0.061		0.0050	After Carbon Bed Sample	
GC1213-BELPSD-BED2S-Lag	12/20/2013	<0.0050		0.0050	After Carbon Bed Sample	
GC1113-BELPSD-PT	11/22/2013	0.32		0.0050	Prior to Treatment Sample	
GC1113-BELPSD-BED1N-Lead-D	11/22/2013	0.057		0.0050	After Carbon Bed Sample-duplicate	
GC1113-BELPSD-BED1N-Lead	11/22/2013	0.047		0.0050	After Carbon Bed Sample	
GC1113-BELPSD-BED2N-Lag	11/22/2013	<0.0050		0.0050	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC1113-BELPSD-BED1S-Lead	11/22/2013	0.065		0.0050	After Carbon Bed Sample	
GC1113-BELPSD-BED2S-Lag	11/22/2013	<0.0050		0.0050	After Carbon Bed Sample	
GC1013-BELPSD-PT	10/22/2013	0.30		0.0050	Prior to Treatment Sample	
GC1013-BELPSD-BED1N-Lead	10/22/2013	0.042		0.0050	After Carbon Bed Sample	
GC1013-BELPSD-BED1N-Lead-D	10/22/2013	0.039		0.0050	After Carbon Bed Sample-duplicate	
GC1013-BELPSD-BED2N-Lag	10/22/2013	<0.0050		0.0050	After Carbon Bed Sample	
GC1013-BELPSD-BED1S-Lead	10/22/2013	0.050		0.0050	After Carbon Bed Sample	
GC1013-BELPSD-BED2S-Lag	10/22/2013	<0.0050		0.0050	After Carbon Bed Sample	
GC0913-BELPSD-PT	9/25/2013	0.27	0.00038	0.0019	Prior to Treatment Sample	
GC0913-BELPSD-BED1N-Lead-D	9/25/2013	0.029	0.00038	0.0019	After Carbon Bed Sample-duplicate	
GC0913-BELPSD-BED1N-Lead	9/25/2013	0.023	0.00038	0.0019	After Carbon Bed Sample	
GC0913-BELPSD-BED2N-Lag	9/25/2013	0.0026	0.00038	0.0019	After Carbon Bed Sample	
GC0913-BELPSD-BED1S-Lead	9/25/2013	0.029	0.00038	0.0019	After Carbon Bed Sample	
GC0913-BELPSD-BED2S-Lag	9/25/2013	0.0034	0.00038	0.0019	After Carbon Bed Sample	
GC0813-BELPSD-PT	8/20/2013	0.27	0.001	0.005	Prior to Treatment Sample	
GC0813-BELPSD-BED1N-Lead	8/20/2013	0.013	0.001	0.005	After Carbon Bed Sample	
GC0813-BELPSD-BED1N-Lead-D	8/20/2013	0.013	0.001	0.005	After Carbon Bed Sample-duplicate	
GC0813-BELPSD-BED2N-Lag	8/20/2013	ND	0.0010	0.0050	After Carbon Bed Sample	
GC0813-BELPSD-BED1S-Lead	8/20/2013	0.011	0.001	0.005	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0813-BELPSD-BED2S-Lag	8/20/2013	ND	0.0010	0.0050	After Carbon Bed Sample	
GC0713-BELPSD-PT	7/31/2013	0.26	0.001	0.005	Prior to Treatment Sample	Carbon Changeout 7/25/13
GC0713-BELPSD-BED1N-Lead-D	7/31/2013	0.0088	0.001	0.005	After Carbon Bed Sample-duplicate	Carbon Changeout 7/25/13
GC0713-BELPSD-BED1N-Lead	7/31/2013	0.0092	0.001	0.005	After Carbon Bed Sample	Carbon Changeout 7/25/13
GC0713-BELPSD-BED2N-Lag	7/31/2013	ND	0.001	0.005	After Carbon Bed Sample	Carbon Changeout 7/25/13
GC0713-BELPSD-BED1S-Lead	7/31/2013	0.0074	0.001	0.005	After Carbon Bed Sample	Carbon Changeout 7/25/13
GC0713-BELPSD-BED2S-Lag	7/31/2013	ND	0.001	0.005	After Carbon Bed Sample	Carbon Changeout 7/25/13
GC0613-BELPSD-PT	6/19/2013	0.31	0.00086	0.0043	Prior to Treatment Sample	
GC0613-BELPSD-BED2N-Lead	6/19/2013	0.12	0.00086	0.0043	After Carbon Bed Sample	
GC0613-BELPSD-BED1N-Lag	6/19/2013	NQ	0.00086	0.0043	After Carbon Bed Sample	
GC0613-BELPSD-BED1N-Lag-D	6/19/2013	ND	0.00086	0.0043	After Carbon Bed Sample-duplicate	
GC0613-BELPSD-BED2S-Lead	6/19/2013	0.13	0.00086	0.0043	After Carbon Bed Sample	
GC0613-BELPSD-BED1S-Lag	6/19/2013	NQ	0.00086	0.0043	After Carbon Bed Sample	
GC0513-BELPSD-PT	5/21/2013	0.36	0.00086	0.0043	Prior to Treatment Sample	
GC0513-BELPSD-BED2N-Lead	5/21/2013	0.12	0.00086	0.0043	After Carbon Bed Sample	
GC0513-BELPSD-BED1N-Lag-D	5/21/2013	ND	0.00086	0.0043	After Carbon Bed Sample-duplicate	
GC0513-BELPSD-BED1N-Lag	5/21/2013	ND	0.00086	0.0043	After Carbon Bed Sample	
GC0513-BELPSD-BED2S-Lead	5/21/2013	0.14	0.00086	0.0043	After Carbon Bed Sample	
GC0513-BELPSD-BED1S-Lag	5/21/2013	ND	0.00086	0.0043	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GC0413-BELPSD-PT	4/18/2013	0.37	0.0011	0.0055	Prior to Treatment Sample	
GC0413-BELPSD-BED2N-Lead	4/18/2013	ND	0.0011	0.0055	After Carbon Bed Sample	Results appear to be inconsistent with historical data
GC0413-BELPSD-BED1N-Lag-D	4/18/2013	ND	0.0011	0.0055	After Carbon Bed Sample-duplicate	
GC0413-BELPSD-BED1N-Lag	4/18/2013	ND	0.0011	0.0055	After Carbon Bed Sample	
GC0413-BELPSD-BED2S-Lead	4/18/2013	0.095	0.0011	0.0055	After Carbon Bed Sample	
GC0413-BELPSD-BED1S-Lag	4/18/2013	0.083	0.0011	0.0055	After Carbon Bed Sample	Results appear to be inconsistent with historical data
WWO-D-BELPSD-PT	3/22/2013	0.45	0.0011	0.0055	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	3/22/2013	0.094 K	0.0011	0.0055	After Carbon Bed Sample	Analyte present. Reported value may be biased high.
WWO-D-BELPSD-BED1N-LAG-2	3/22/2013	ND	0.0011	0.0055	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	3/22/2013	ND	0.0011	0.0055	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	3/22/2013	0.11	0.0011	0.0055	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	3/22/2013	ND	0.0011	0.0055	After Carbon Bed Sample	
WWO-D-BELPSD-PT	2/19/2013	0.38	0.0024	0.012	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	2/19/2013	0.046	0.0024	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	2/19/2013	ND	0.0024	0.012	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	2/19/2013	ND	0.0024	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	2/19/2013	0.053	0.0024	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	2/19/2013	ND	0.0024	0.012	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-PT	1/24/2013	0.30	0.0039	0.020	Prior to Treatment Sample	Carbon Changeout 1/3/2013
WWO-D-BELPSD-BED2N-LEAD	1/24/2013	NQ	0.0039	0.020	After Carbon Bed Sample	Carbon Changeout 1/3/2013
WWO-D-BELPSD-BED1N-LAG-2	1/24/2013	ND	0.0039	0.020	After Carbon Bed Sample-duplicate	Carbon Changeout 1/3/2013
WWO-D-BELPSD-BED1N-LAG	1/24/2013	ND	0.0039	0.020	After Carbon Bed Sample	Carbon Changeout 1/3/2013
WWO-D-BELPSD-BED2S-LEAD	1/24/2013	NQ	0.0039	0.020	After Carbon Bed Sample	Carbon Changeout 1/3/2013
WWO-D-BELPSD-BED1S-LAG	1/24/2013	ND	0.0039	0.020	After Carbon Bed Sample	Carbon Changeout 1/3/2013
WWO-D-BELPSD-PT	12/19/2012	0.24	0.0039	0.020	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	12/19/2012	0.086	0.0039	0.020	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	12/19/2012	0.093	0.0039	0.020	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	12/19/2012	ND	0.0039	0.020	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	12/19/2012	0.094	0.0039	0.020	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	12/19/2012	ND	0.0039	0.020	After Carbon Bed Sample	
WWO-D-BELPSD-PT	11/27/2012	0.49	0.0025	0.012	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	11/27/2012	0.14	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	11/27/2012	0.13	0.0025	0.012	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	11/27/2012	ND	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	11/27/2012	0.16	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	11/27/2012	NQ	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-PT	10/23/2012	0.36	0.0018	0.0091	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LEAD-2	10/23/2012	0.081	0.0018	0.0091	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	10/23/2012	0.077	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	10/23/2012	ND	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	10/23/2012	0.089	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	10/23/2012	NQ	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-PT	9/26/2012	0.36	0.0018	0.0091	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	9/26/2012	0.065 J	0.0018	0.0091	After Carbon Bed Sample	Analyte present. Reported value may not be accurate or precise.
WWO-D-BELPSD-BED1N-LEAD-2	9/26/2012	0.052 J	0.0018	0.0091	After Carbon Bed Sample-duplicate	Analyte present. Reported value may not be accurate or precise.
WWO-D-BELPSD-BED2N-LAG	9/26/2012	ND	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	9/26/2012	0.082	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	9/26/2012	ND	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-PT	8/21/2012	0.41	0.0018	0.0091	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	8/21/2012	0.044	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	8/21/2012	0.043	0.0018	0.0091	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	8/21/2012	ND	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	8/21/2012	0.045	0.0018	0.0091	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	8/21/2012	ND	0.0018	0.0091	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-PT	7/20/2012	0.34	0.0032	0.016	Prior to Treatment Sample	Carbon Changeout 7/11/2012
WWO-D-BELPSD-BED1N-LEAD-2	7/20/2012	0.023	0.0032	0.016	After Carbon Bed Sample-duplicate	Carbon Changeout 7/11/2012
WWO-D-BELPSD-BED1N-LEAD	7/20/2012	0.025	0.0032	0.016	After Carbon Bed Sample	Carbon Changeout 7/11/2012
WWO-D-BELPSD-BED2N-LAG	7/20/2012	ND	0.0032	0.016	After Carbon Bed Sample	Carbon Changeout 7/11/2012
WWO-D-BELPSD-BED1S-LEAD	7/20/2012	0.026	0.0032	0.016	After Carbon Bed Sample	Carbon Changeout 7/11/2012
WWO-D-BELPSD-BED2S-LAG	7/20/2012	ND	0.0032	0.016	After Carbon Bed Sample	Carbon Changeout 7/11/2012
WWO-D-BELPSD-PT	6/21/2012	0.27	0.022	0.11	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	6/21/2012	0.16	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	6/21/2012	NQ	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	6/21/2012	NQ	0.0022	0.011	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	6/21/2012	0.15	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	6/21/2012	NQ	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-PT	5/18/2012	0.34	0.0022	0.011	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	5/18/2012	0.14	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	5/18/2012	ND	0.0022	0.011	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	5/18/2012	NQ	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	5/18/2012	0.16	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	5/18/2012	NQ	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-PT	4/26/2012	0.28	0.0022	0.011	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2N-LEAD	4/26/2012	0.13	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	4/26/2012	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	4/26/2012	ND	0.0022	0.011	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	4/26/2012	0.12	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	4/26/2012	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-PT	3/27/2012	0.29	0.0031	0.015	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	3/27/2012	0.10	0.0031	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	3/27/2012	ND	0.0031	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	3/27/2012	ND	0.0031	0.015	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	3/27/2012	0.11	0.0031	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	3/27/2012	ND	0.0031	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-PT	2/21/2012	0.31	0.0022	0.011	Prior to Treatment Sample	
WWO-D-BELPSD-PT	2/21/2012	0.040 R	0.0031	0.015	Prior to Treatment Sample	Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED2N-LEAD	2/21/2012	0.023 R	0.0031	0.015	After Carbon Bed Sample	Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED2N-LEAD	2/21/2012	0.088	0.0022	0.011	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LAG	2/21/2012	ND R	0.0031	0.015	After Carbon Bed Sample	Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED1N-LAG-2	2/21/2012	ND R	0.0031	0.015	After Carbon Bed Sample-duplicate	Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED1N-LAG-2	2/21/2012	ND	0.0022	0.011	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	2/21/2012	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	2/21/2012	0.095	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	2/21/2012	0.023 R	0.0031	0.015	After Carbon Bed Sample	Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED1S-LAG	2/21/2012	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	2/21/2012	ND R	0.0031	0.015	After Carbon Bed Sample	Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-PT	1/20/2012	0.28	0.0031	0.015	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	1/20/2012	0.042	0.0031	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	1/20/2012	ND	0.0031	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	1/20/2012	ND	0.0031	0.015	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	1/20/2012	0.071	0.0031	0.015	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1S-LAG	1/20/2012	ND	0.0031	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-PT	12/30/2011	0.33	0.0031	0.015	Prior to Treatment Sample	Carbon Changeout 12/29/2011
WWO-D-BELPSD-BED2N-LEAD	12/30/2011	0.024	0.0031	0.015	After Carbon Bed Sample	Carbon Changeout 12/29/2011
WWO-D-BELPSD-BED1N-LAG-2	12/30/2011	ND	0.0031	0.015	After Carbon Bed Sample-duplicate	Carbon Changeout 12/29/2011
WWO-D-BELPSD-BED1N-LAG	12/30/2011	ND	0.0031	0.015	After Carbon Bed Sample	Carbon Changeout 12/29/2011
WWO-D-BELPSD-BED2S-LEAD	12/30/2011	0.040	0.0031	0.015	After Carbon Bed Sample	Carbon Changeout 12/29/2011
WWO-D-BELPSD-BED1S-LAG	12/30/2011	ND	0.0031	0.015	After Carbon Bed Sample	Carbon Changeout 12/29/2011
WWO-D-BELPSD-PT	11/22/2011	0.30	0.0030	0.015	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	11/22/2011	0.15 J	0.0030	0.015	After Carbon Bed Sample	Analyte present. Reported value may not be accurate or precise.
WWO-D-BELPSD-BED1N-LEAD-2	11/22/2011	0.12 J	0.0030	0.015	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	11/22/2011	NQ	0.0030	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	11/22/2011	0.14	0.0030	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	11/22/2011	NQ	0.0030	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-PT	10/19/2011	0.26	0.0030	0.015	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	10/19/2011	0.12	0.0030	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	10/19/2011	0.12	0.0030	0.015	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	10/19/2011	NQ	0.0030	0.015	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1S-LEAD	10/19/2011	0.11	0.0030	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	10/19/2011	NQ	0.0030	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-PT	9/21/2011	0.28	0.0018	0.0092	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	9/21/2011	0.11	0.0018	0.0092	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	9/21/2011	0.11	0.0018	0.0092	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	9/21/2011	NQ	0.0018	0.0092	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	9/21/2011	0.13	0.0018	0.0092	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	9/21/2011	NQ	0.0018	0.0092	After Carbon Bed Sample	
WWO-D-BELPSD-PT	8/24/2011	0.35	0.0032	0.016	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	8/24/2011	0.12	0.0032	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	8/24/2011	0.14	0.0032	0.016	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	8/24/2011	ND	0.0032	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	8/24/2011	0.16	0.0032	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	8/24/2011	ND	0.0032	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-PT	7/22/2011	9.5 R	0.034	0.17	Prior to Treatment Sample	Results deemed invalid by MPI., Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LEAD-2	7/22/2011	0.11 R	0.0034	0.017	After Carbon Bed Sample-duplicate	Results deemed invalid by MPI., Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED1N-LEAD	7/22/2011	0.10 R	0.0034	0.017	After Carbon Bed Sample	Results deemed invalid by MPI., Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED2N-LAG	7/22/2011	ND R	0.0034	0.017	After Carbon Bed Sample	Results deemed invalid by MPI., Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED1S-LEAD	7/22/2011	0.10 R	0.0034	0.017	After Carbon Bed Sample	Results deemed invalid by MPI., Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-BED2S-LAG	7/22/2011	ND R	0.0034	0.017	After Carbon Bed Sample	Results deemed invalid by MPI., Unusable result. Analyte may or may not be present in sample, though reported analytical result is ND.
WWO-D-BELPSD-PT	6/21/2011	0.36	0.0029	0.015	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	6/21/2011	0.081	0.0029	0.015	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	6/21/2011	0.090	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	6/21/2011	ND	0.0029	0.015	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1S-LEAD	6/21/2011	0.11	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	6/21/2011	ND	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-PT	5/20/2011	0.23	0.0029	0.015	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	5/20/2011	0.049	0.0029	0.015	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	5/20/2011	0.054	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	5/20/2011	ND	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	5/20/2011	0.057	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	5/20/2011	ND	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-PT	4/21/2011	0.23	0.0029	0.015	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	4/21/2011	0.033	0.0029	0.015	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	4/21/2011	0.033	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	4/21/2011	ND	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	4/21/2011	0.036	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	4/21/2011	ND	0.0029	0.015	After Carbon Bed Sample	
WWO-D-BELPSD-PT	3/24/2011	0.34	0.0029	0.015	Prior to Treatment Sample	Carbon Changeout 3/22/2011
WWO-D-BELPSD-BED1N-LEAD	3/24/2011	NQ	0.0029	0.015	After Carbon Bed Sample	Carbon Changeout 3/22/2011
WWO-D-BELPSD-BED1N-LEAD-2	3/24/2011	NQ	0.0029	0.015	After Carbon Bed Sample-duplicate	Carbon Changeout 3/22/2011
WWO-D-BELPSD-BED2N-LAG	3/24/2011	ND	0.0029	0.015	After Carbon Bed Sample	Carbon Changeout 3/22/2011
WWO-D-BELPSD-BED1S-LEAD	3/24/2011	NQ	0.0029	0.015	After Carbon Bed Sample	Carbon Changeout 3/22/2011

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2S-LAG	3/24/2011	ND	0.0029	0.015	After Carbon Bed Sample	Carbon Changeout 3/22/2011
WWO-D-BELPSD-PT	2/18/2011	0.34	0.0028	0.014	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	2/18/2011	0.15	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	2/18/2011	NQ	0.0028	0.014	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	2/18/2011	NQ	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	2/18/2011	0.10	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	2/18/2011	NQ	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-PT	1/21/2011	0.25	0.0028	0.014	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	1/21/2011	0.11	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	1/21/2011	ND	0.0028	0.014	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	1/21/2011	ND	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	1/21/2011	0.092	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	1/21/2011	ND	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-PT	12/21/2010	0.26	0.0028	0.014	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	12/21/2010	0.090	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	12/21/2010	ND	0.0028	0.014	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	12/21/2010	ND	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	12/21/2010	0.071	0.0028	0.014	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	12/21/2010	ND	0.0028	0.014	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-PT	11/22/2010	0.22	0.0036	0.018	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	11/22/2010	0.042	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	11/22/2010	ND	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	11/22/2010	ND	0.0036	0.018	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	11/22/2010	0.046	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	11/22/2010	ND	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-PT	10/25/2010	0.24	0.0036	0.018	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	10/25/2010	0.058	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	10/25/2010	ND	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	10/25/2010	ND	0.0036	0.018	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	10/25/2010	0.042	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	10/25/2010	ND	0.0036	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-PT	9/22/2010	0.33	0.0025	0.012	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	9/22/2010	0.041	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	9/22/2010	ND	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	9/22/2010	ND	0.0025	0.012	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	9/22/2010	0.043	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	9/22/2010	ND	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-PT	8/30/2010	0.22	0.0025	0.012	Prior to Treatment Sample	Carbon Changeout 8/26/2010

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2N-LEAD	8/30/2010	0.016	0.0025	0.012	After Carbon Bed Sample	Carbon Changeout 8/26/2010
WWO-D-BELPSD-BED1N-LAG	8/30/2010	ND	0.0025	0.012	After Carbon Bed Sample	Carbon Changeout 8/26/2010
WWO-D-BELPSD-BED1N-LAG-2	8/30/2010	ND	0.0025	0.012	After Carbon Bed Sample-duplicate	Carbon Changeout 8/26/2010
WWO-D-BELPSD-BED2S-LEAD	8/30/2010	0.016	0.0025	0.012	After Carbon Bed Sample	Carbon Changeout 8/26/2010
WWO-D-BELPSD-BED1S-LAG	8/30/2010	ND	0.0025	0.012	After Carbon Bed Sample	Carbon Changeout 8/26/2010
WWO-D-BELPSD-PT	7/22/2010	0.30	0.0025	0.012	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	7/22/2010	0.086	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	7/22/2010	0.073	0.0025	0.012	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	7/22/2010	NQ	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	7/22/2010	0.096	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	7/22/2010	NQ	0.0025	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-PT	6/24/2010	0.28	0.0038	0.019	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	6/24/2010	0.068	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	6/24/2010	0.056	0.0038	0.019	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	6/24/2010	ND	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	6/24/2010	0.072	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	6/24/2010	ND	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-PT	5/19/2010	0.24	0.0038	0.019	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	5/19/2010	0.042	0.0038	0.019	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LEAD-2	5/19/2010	0.050	0.0038	0.019	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	5/19/2010	ND	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	5/19/2010	0.046	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	5/19/2010	ND	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-PT	4/28/2010	0.29	0.0038	0.019	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	4/28/2010	0.052	0.0038	0.019	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	4/28/2010	0.056	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	4/28/2010	ND	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	4/28/2010	0.050	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	4/28/2010	ND	0.0038	0.019	After Carbon Bed Sample	
WWO-D-BELPSD-PT	3/23/2010	0.24	0.0035	0.018	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	3/23/2010	0.036	0.0035	0.018	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	3/23/2010	0.040	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	3/23/2010	ND	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	3/23/2010	0.034	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	3/23/2010	ND	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-PT	2/26/2010	0.27	0.0035	0.018	Prior to Treatment Sample	Carbon Changeout 2/25/2010
WWO-D-BELPSD-BED1N-LEAD-2	2/26/2010	0.025	0.0035	0.018	After Carbon Bed Sample-duplicate	Carbon Changeout 2/25/2010
WWO-D-BELPSD-BED1N-LEAD	2/26/2010	0.023	0.0035	0.018	After Carbon Bed Sample	Carbon Changeout 2/25/2010

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2N-LAG	2/26/2010	ND	0.0035	0.018	After Carbon Bed Sample	Carbon Changeout 2/25/2010
WWO-D-BELPSD-BED1S-LEAD	2/26/2010	0.018	0.0035	0.018	After Carbon Bed Sample	Carbon Changeout 2/25/2010
WWO-D-BELPSD-BED2S-LAG	2/26/2010	ND	0.0035	0.018	After Carbon Bed Sample	Carbon Changeout 2/25/2010
WWO-D-BELPSD-PT	1/22/2010	0.25	0.0035	0.018	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	1/22/2010	0.12	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	1/22/2010	NQ	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	1/22/2010	NQ	0.0035	0.018	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	1/22/2010	0.11	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	1/22/2010	ND	0.0035	0.018	After Carbon Bed Sample	
WWO-D-BELPSD-PT	12/15/2009	0.22	0.0033	0.016	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	12/15/2009	0.097	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	12/15/2009	ND	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	12/15/2009	ND	0.0033	0.016	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	12/15/2009	0.11	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	12/15/2009	ND	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-PT	11/19/2009	0.23	0.0033	0.016	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	11/19/2009	0.10	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	11/19/2009	ND	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	11/19/2009	ND	0.0033	0.016	After Carbon Bed Sample-duplicate	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2S-LEAD	11/19/2009	0.11	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	11/19/2009	ND	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-PT	10/27/2009	0.26	0.0033	0.016	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	10/27/2009	0.084	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	10/27/2009	ND	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	10/27/2009	ND	0.0033	0.016	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	10/27/2009	0.093	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	10/27/2009	ND	0.0033	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-PT	9/23/2009	0.27	0.0033	0.016	Prior to Treatment Sample	Carbon Changeout 9/2/2009
WWO-D-BELPSD-BED2N-LEAD	9/23/2009	0.054	0.0033	0.016	After Carbon Bed Sample	Carbon Changeout 9/2/2009
WWO-D-BELPSD-BED1N-LAG	9/23/2009	ND	0.0033	0.016	After Carbon Bed Sample	Carbon Changeout 9/2/2009
WWO-D-BELPSD-BED1N-LAG-2	9/23/2009	ND	0.0033	0.016	After Carbon Bed Sample-duplicate	Carbon Changeout 9/2/2009
WWO-D-BELPSD-BED2S-LEAD	9/23/2009	0.074	0.0033	0.016	After Carbon Bed Sample	Carbon Changeout 9/2/2009
WWO-D-BELPSD-BED1S-LAG	9/23/2009	ND	0.0033	0.016	After Carbon Bed Sample	Carbon Changeout 9/2/2009
WWO-D-BELPSD-PT	8/21/2009	0.28	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	8/21/2009	0.11	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	8/21/2009	0.088	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	8/21/2009	0.014	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	8/21/2009	0.12	0.0026	0.013	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2S-LAG	8/21/2009	0.023	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	7/23/2009	0.25	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	7/23/2009	0.11	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	7/23/2009	0.097	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	7/23/2009	NQ	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	7/23/2009	0.083	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	7/23/2009	0.015	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	6/25/2009	0.30	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	6/25/2009	0.084	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	6/25/2009	0.081	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	6/25/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	6/25/2009	0.080	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	6/25/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	5/14/2009	0.26	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	5/14/2009	0.053	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	5/14/2009	0.042	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	5/14/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	5/14/2009	0.046	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	5/14/2009	ND	0.0026	0.013	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-PT	4/23/2009	0.26	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	4/23/2009	0.033	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	4/23/2009	0.033	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	4/23/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	4/23/2009	0.033	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	4/23/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	3/26/2009	0.25	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	3/26/2009	0.026	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	3/26/2009	0.030	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	3/26/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	3/26/2009	0.024	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	3/26/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	2/26/2009	0.21	0.0026	0.013	Prior to Treatment Sample	Carbon Changeout 2/25/2009
WWO-D-BELPSD-BED1N-LEAD	2/26/2009	0.017	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 2/25/2009
WWO-D-BELPSD-BED1N-LEAD-2	2/26/2009	0.019	0.0026	0.013	After Carbon Bed Sample-duplicate	Carbon Changeout 2/25/2009
WWO-D-BELPSD-BED2N-LAG	2/26/2009	ND	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 2/25/2009
WWO-D-BELPSD-BED1S-LEAD	2/26/2009	ND	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 2/25/2009
WWO-D-BELPSD-BED2S-LAG	2/26/2009	ND	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 2/25/2009
WWO-D-BELPSD-PT	1/22/2009	0.23	0.0026	0.013	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2N-LEAD	1/22/2009	0.090	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	1/22/2009	NQ	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	1/22/2009	NQ	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	1/22/2009	0.098	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	1/22/2009	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	12/16/2008	0.22	0.0017	0.0085	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	12/16/2008	0.047	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	12/16/2008	ND	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	12/16/2008	ND	0.0017	0.0085	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	12/16/2008	0.080	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	12/16/2008	ND	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-PT	11/21/2008	0.19	0.0017	0.0085	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	11/21/2008	0.044	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	11/21/2008	ND	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	11/21/2008	ND	0.0017	0.0085	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	11/21/2008	0.066	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	11/21/2008	ND	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-PT	10/20/2008	0.17	0.0017	0.0085	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	10/20/2008	0.033	0.0017	0.0085	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LAG	10/20/2008	ND	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	10/20/2008	ND	0.0017	0.0085	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	10/20/2008	0.070	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	10/20/2008	ND	0.0017	0.0085	After Carbon Bed Sample	
WWO-D-BELPSD-PT	9/10/2008	0.23	0.0023	0.012	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	9/10/2008	0.014	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	9/10/2008	ND	0.0023	0.012	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	9/10/2008	ND	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	9/10/2008	0.062	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	9/10/2008	ND	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-PT	8/11/2008	0.15	0.0023	0.012	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	8/11/2008	ND	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	8/11/2008	ND	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	8/11/2008	ND	0.0023	0.012	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	8/11/2008	0.051	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	8/11/2008	ND	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-PT	7/16/2008	0.18	0.0023	0.012	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	7/16/2008	ND	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	7/16/2008	ND	0.0023	0.012	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LAG-2	7/16/2008	ND	0.0023	0.012	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	7/16/2008	0.048	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	7/16/2008	ND	0.0023	0.012	After Carbon Bed Sample	
WWO-D-BELPSD-PT	6/13/2008	0.18	0.0019	0.0096	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	6/13/2008	ND	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	6/13/2008	ND	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	6/13/2008	ND	0.0019	0.0096	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	6/13/2008	0.022	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	6/13/2008	ND	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-PT	5/27/2008	0.18	0.0019	0.0096	Prior to Treatment Sample	Carbon Changeout 5/15/2008
WWO-D-BELPSD-BED2N-LEAD	5/27/2008	ND	0.0019	0.0096	After Carbon Bed Sample	Carbon Changeout 5/15/2008
WWO-D-BELPSD-BED1N-LAG	5/27/2008	ND	0.0019	0.0096	After Carbon Bed Sample	Carbon Changeout 5/15/2008
WWO-D-BELPSD-BED1N-LAG-2	5/27/2008	ND	0.0019	0.0096	After Carbon Bed Sample-duplicate	Carbon Changeout 5/15/2008
WWO-D-BELPSD-BED2S-LEAD	5/27/2008	NQ	0.0019	0.0096	After Carbon Bed Sample	Carbon Changeout 5/15/2008
WWO-D-BELPSD-BED1S-LAG	5/27/2008	ND	0.0019	0.0096	After Carbon Bed Sample	Carbon Changeout 5/15/2008
WWO-D-BELPSD-COMBINEDEFF	4/18/2008	0.018	0.0019	0.0096		
WWO-D-BELPSD-PT	4/18/2008	0.22	0.0019	0.0096	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	4/18/2008	0.033	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	4/18/2008	0.017	0.0019	0.0096	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-PT	4/3/2008	0.18	0.0019	0.0096	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	4/3/2008	NQ	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	4/3/2008	ND	0.0019	0.0096	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	4/3/2008	0.031	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	4/3/2008	0.066	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	4/3/2008	ND	0.0019	0.0096	After Carbon Bed Sample	
WWO-D-BELPSD-PT	3/12/2008	0.21	0.0022	0.011	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	3/12/2008	ND	0.0022	0.011	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	3/12/2008	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	3/12/2008	0.018	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	3/12/2008	0.059	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	3/12/2008	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-PT	2/12/2008	0.23	0.0022	0.011	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	2/12/2008	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	2/12/2008	ND	0.0022	0.011	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	2/12/2008	NQ	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	2/12/2008	0.046	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	2/12/2008	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-PT	1/16/2008	0.22	0.0022	0.011	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LEAD-2	1/16/2008	ND	0.0022	0.011	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	1/16/2008	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	1/16/2008	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	1/16/2008	0.036	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	1/16/2008	ND	0.0022	0.011	After Carbon Bed Sample	
WWO-D-BELPSD-PT	12/11/2007	0.22	0.0031	0.016	Prior to Treatment Sample	Carbon Changeout 12/6/2007
WWO-D-BELPSD-BED1N-LEAD-2	12/11/2007	ND	0.0031	0.016	After Carbon Bed Sample-duplicate	Carbon Changeout 12/6/2007
WWO-D-BELPSD-BED1N-LEAD	12/11/2007	ND	0.0031	0.016	After Carbon Bed Sample	Carbon Changeout 12/6/2007
WWO-D-BELPSD-BED2N-LAG	12/11/2007	ND	0.0031	0.016	After Carbon Bed Sample	Carbon Changeout 12/6/2007
WWO-D-BELPSD-BED1S-LEAD	12/11/2007	NQ	0.0031	0.016	After Carbon Bed Sample	Carbon Changeout 12/6/2007
WWO-D-BELPSD-BED2S-LAG	12/11/2007	ND	0.0031	0.016	After Carbon Bed Sample	Carbon Changeout 12/6/2007
WWO-D-BELPSD-PT	11/13/2007	0.22	0.0031	0.016	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	11/13/2007	0.10	0.0031	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	11/13/2007	NQ	0.0031	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	11/13/2007	NQ	0.0031	0.016	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2S-LEAD	11/13/2007	0.11	0.0031	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	11/13/2007	NQ	0.0031	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-PT	10/3/2007	0.22	0.0031	0.016	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	10/3/2007	0.073	0.0031	0.016	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LAG-2	10/3/2007	0.071	0.0031	0.016	After Carbon Bed Sample-duplicate	Results appear to be inconsistent with historical data
WWO-D-BELPSD-BED1N-LAG	10/3/2007	ND	0.0031	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	10/3/2007	0.097	0.0031	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	10/3/2007	ND	0.0031	0.016	After Carbon Bed Sample	
WWO-D-BELPSD-PT	9/12/2007	0.25 J	0.0012	0.0062	Prior to Treatment Sample	Analyte present. Reported value may not be accurate or precise.
WWO-D-BELPSD-BED2N-LEAD	9/12/2007	0.079	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	9/12/2007	ND	0.0012	0.0062	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	9/12/2007	ND	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	9/12/2007	0.10	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	9/12/2007	ND	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-PT	8/14/2007	0.22	0.0012	0.0062	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	8/14/2007	0.072	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	8/14/2007	ND	0.0012	0.0062	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	8/14/2007	ND	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	8/14/2007	0.079	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	8/14/2007	ND	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-PT	7/19/2007	0.18	0.0012	0.0062	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2N-LEAD	7/19/2007	0.052	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	7/19/2007	ND	0.0012	0.0062	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	7/19/2007	ND	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	7/19/2007	0.049	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	7/19/2007	ND	0.0012	0.0062	After Carbon Bed Sample	
WWO-D-BELPSD-PT	6/22/2007	0.19	0.0012	0.0062	Prior to Treatment Sample	Carbon Changeout 6/19/2007
WWO-D-BELPSD-BED2N-LEAD	6/22/2007	0.029	0.0012	0.0062	After Carbon Bed Sample	Carbon Changeout 6/19/2007
WWO-D-BELPSD-BED1N-LAG	6/22/2007	NQ	0.0012	0.0062	After Carbon Bed Sample	Carbon Changeout 6/19/2007
WWO-D-BELPSD-BED1N-LAG-2	6/22/2007	NQ	0.0012	0.0062	After Carbon Bed Sample-duplicate	Carbon Changeout 6/19/2007
WWO-D-BELPSD-BED2S-LEAD	6/22/2007	0.034	0.0012	0.0062	After Carbon Bed Sample	Carbon Changeout 6/19/2007
WWO-D-BELPSD-BED1S-LAG	6/22/2007	NQ	0.0012	0.0062	After Carbon Bed Sample	Carbon Changeout 6/19/2007
WWO-D-BELPSD-PT	5/17/2007	0.21	0.0027	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	5/17/2007	0.077	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	5/17/2007	0.076	0.0027	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	5/17/2007	NQ	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	5/17/2007	0.078	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	5/17/2007	NQ	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	4/19/2007	0.22	0.0027	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	4/19/2007	0.059	0.0027	0.013	After Carbon Bed Sample-duplicate	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED1N-LEAD	4/19/2007	0.053	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	4/19/2007	ND	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	4/19/2007	0.057	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	4/19/2007	ND	0.0027	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	3/27/2007	0.20	0.0010	0.0051	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	3/27/2007	0.046	0.0010	0.0051	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	3/27/2007	0.048	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	3/27/2007	ND	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	3/27/2007	0.043	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	3/27/2007	ND	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-PT	2/15/2007	0.19	0.0010	0.0051	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	2/15/2007	0.026	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	2/15/2007	0.026	0.0010	0.0051	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	2/15/2007	ND	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	2/15/2007	0.019	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	2/15/2007	ND	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-PT	1/15/2007	0.22	0.0010	0.0051	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	1/15/2007	0.0079	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	1/15/2007	0.0069	0.0010	0.0051	After Carbon Bed Sample-duplicate	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2N-LAG	1/15/2007	NQ	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	1/15/2007	0.0060	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	1/15/2007	NQ	0.0010	0.0051	After Carbon Bed Sample	
WWO-D-BELPSD-PT	12/14/2006	0.17	0.0018	0.0090	Prior to Treatment Sample	Carbon Changeout 11/28/2006
WWO-D-BELPSD-BED1N-LEAD	12/14/2006	ND	0.0018	0.0090	After Carbon Bed Sample	Carbon Changeout 11/28/2006
WWO-D-BELPSD-BED1N-LEAD-2	12/14/2006	ND	0.0018	0.0090	After Carbon Bed Sample-duplicate	Carbon Changeout 11/28/2006
WWO-D-BELPSD-BED2N-LAG	12/14/2006	ND	0.0018	0.0090	After Carbon Bed Sample	Carbon Changeout 11/28/2006
WWO-D-BELPSD-BED1S-LEAD	12/14/2006	ND	0.0018	0.0090	After Carbon Bed Sample	Carbon Changeout 11/28/2006
WWO-D-BELPSD-BED2S-LAG	12/14/2006	ND	0.0018	0.0090	After Carbon Bed Sample	Carbon Changeout 11/28/2006
WWO-D-BELPSD-PT	11/7/2006	0.18	0.0018	0.0090	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	11/7/2006	0.018	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	11/7/2006	ND	0.0018	0.0090	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	11/7/2006	ND	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	11/7/2006	0.014	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	11/7/2006	ND	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-PT	10/10/2006	0.23	0.0018	0.0090	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	10/10/2006	0.010	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG	10/10/2006	ND	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	10/10/2006	ND	0.0018	0.0090	After Carbon Bed Sample-duplicate	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2S-LEAD	10/10/2006	NQ	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	10/10/2006	ND	0.0018	0.0090	After Carbon Bed Sample	
WWO-D-BELPSD-PT	9/19/2006	0.18	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED2N-LEAD	9/19/2006	NQ	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LAG-2	9/19/2006	ND	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LAG	9/19/2006	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LEAD	9/19/2006	NQ	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LAG	9/19/2006	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	8/23/2006	0.22	0.0026	0.013	Prior to Treatment Sample	Carbon Changeout 8/17/2006
WWO-D-BELPSD-BED2N-LEAD	8/23/2006	ND	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 8/17/2006
WWO-D-BELPSD-BED1N-LAG-2	8/23/2006	ND	0.0026	0.013	After Carbon Bed Sample-duplicate	Carbon Changeout 8/17/2006
WWO-D-BELPSD-BED1N-LAG	8/23/2006	NQ	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 8/17/2006
WWO-D-BELPSD-BED2S-LEAD	8/23/2006	NQ	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 8/17/2006
WWO-D-BELPSD-BED1S-LAG	8/23/2006	ND	0.0026	0.013	After Carbon Bed Sample	Carbon Changeout 8/17/2006
WWO-D-BELPSD-PT	7/27/2006	0.197	0.0026	0.013	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD-2	7/27/2006	0.0137	0.0026	0.013	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED1N-LEAD	7/27/2006	0.014	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	7/27/2006	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	7/27/2006	0.0284	0.0026	0.013	After Carbon Bed Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-BED2S-LAG	7/27/2006	ND	0.0026	0.013	After Carbon Bed Sample	
WWO-D-BELPSD-PT	6/15/2006	0.185	0.0012	0.006	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	6/15/2006	NQ	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-BED1N-LEAD-2	6/15/2006	NQ	0.0012	0.006	After Carbon Bed Sample-duplicate	
WWO-D-BELPSD-BED2N-LAG	6/15/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	6/15/2006	NQ	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	6/15/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-PT	5/9/2006	0.275	0.0012	0.006	Prior to Treatment Sample	
WWO-D-BELPSD-BED1N-LEAD	5/9/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-BED2N-LAG	5/9/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-BED1S-LEAD	5/9/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-BED2S-LAG	5/9/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSDPT	4/24/2006	0.237	0.0012	0.006	Prior to Treatment Sample	
WWO-D-BELPSD-AC-BED1N-LEAD-MS/R	4/24/2006	ND	0.0012	0.006	After Carbon Bed Sample-duplicate	field sample, not QC sample
WWO-D-BELPSD-AC-BED1N-LEAD	4/24/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-AC-BED2N-LAG	4/24/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-AC-BED1S-LEAD	4/24/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSD-AC-BED2S-LAG	4/24/2006	ND	0.0012	0.006	After Carbon Bed Sample	
WWO-D-BELPSDPT	3/13/2006	0.213	0.0023	0.012	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-D-BELPSD-AC-BED1N	3/13/2006	ND	0.0023	0.012	After Carbon Bed Sample	Lead
WWO-D-BELPSD-AC-BED2N	3/13/2006	ND	0.0023	0.012	After Carbon Bed Sample	Lag
WWO-D-BELPSD-AC-BED1S	3/13/2006	ND	0.0023	0.012	After Carbon Bed Sample	Lead
WWO-D-BELPSD-AC-BED2S	3/13/2006	ND	0.0023	0.012	After Carbon Bed Sample	Lag
WWO-D-BELPRE-WQCONFORMATION	3/3/2006	ND	0.0023	0.012	After Carbon Treatment Sample	
WWO-G-BEL PSDPT	3/10/2005	0.138	0.01	0.05	Prior to Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
GAC Construct/Operation Samples						
BW1117-BEL-BACKWASH-FF	11/29/2017	<0.010 UJ		0.010	NPDES Discharge Monitoring	Not detected. Reporting limit may not be accurate or precise.
BW1116-BEL-BACKWASH-FF	11/18/2016	<0.010		0.010	NPDES Discharge Monitoring	
BW0816-BEL-BACKWASH-FF	8/19/2016	0.22		0.0050	NPDES Discharge Monitoring	
BW0116-BEL-BACKWASH-FF	1/22/2016	0.020 J		0.0050	NPDES Discharge Monitoring	Analyte present. Reported value may not be accurate or precise.
BW0215-BEL-BACKWASH-FF	2/19/2015	0.018 J		0.0050	NPDES Discharge Monitoring	Analyte present. Reported value may not be accurate or precise.
BW0414-BEL-BACKWASH-FF	4/11/2014	<0.0050		0.0050	NPDES Discharge Monitoring	
BW0713-BEL-BACKWASH	7/26/2013	ND	0.0010	0.0050	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH	1/4/2013	ND	0.0039	0.020	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH	7/12/2012	ND	0.0032	0.016	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH	12/30/2011	ND	0.0031	0.015	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH	3/23/2011	ND	0.0028	0.014	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH	8/27/2010	ND	0.0025	0.012	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH	2/26/2010	ND	0.0035	0.018	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH	9/3/2009	NQ	0.0026	0.013	NPDES Discharge Monitoring	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-Z-BEL-BACKWASH1	2/26/2009	ND	0.0026	0.013	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH2	2/26/2009	ND	0.0026	0.013	NPDES Discharge Monitoring	
WWO-Z-C-STALL-BELP	2/25/2009	0.077	0.0026	0.013	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH1	5/16/2008	ND	0.0019	0.0096	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH3	5/16/2008	ND	0.0019	0.0096	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH2	5/16/2008	NQ	0.0019	0.0096	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH1	12/7/2007	ND	0.0031	0.016	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH2	12/7/2007	ND	0.0031	0.016	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH1	6/20/2007	ND	0.0012	0.0062	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH2	6/20/2007	NQ	0.0012	0.0062	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH1	11/30/2006	ND	0.0018	0.0090	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH2	11/30/2006	ND	0.0018	0.0090	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH2-2	11/30/2006	ND	0.0018	0.0090	NPDES Discharge Monitoring-duplicate	
WWO-Z-BEL-BACKWASH 2	8/19/2006	ND	0.0026	0.013	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH 1	8/18/2006	ND	0.0026	0.013	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH 1-2	8/18/2006	ND	0.0026	0.013	NPDES Discharge Monitoring-duplicate	
WWO-Z-C-STALL-BELP	8/17/2006	0.073	0.0026	0.013	NPDES Discharge Monitoring	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.

**Table 3. PFOA Results, Carbon Treatment System Samples
Belpre Public Works, Ohio**

Field Sample ID	Date	PFOA	LOD	RL/LOQ	Comments	Notes
WWO-Z-BEL-BACKWASH2	2/10/2006	0.0139	0.0023	0.012	NPDES Discharge Monitoring	
WWO-Z-BEL-BACKWASH1	2/9/2006	0.0179	0.0023	0.012	NPDES Discharge Monitoring	
WWO-Z-C-STALL-BELP	2/3/2006	0.105	0.0023	0.012	NPDES Discharge Monitoring	
WWO-Z-HYDRO H2O-BEL	1/27/2006	0.204	0.0023	0.012	NPDES Discharge Monitoring	
Water Prior to Installation of GAC System						
WWO-D-BELPSDAT	7/13/2005	0.214	0.0015	0.0073	After Treatment Sample	
WWO-D-BELPSDAT-2	7/13/2005	0.226	0.0015	0.0073	After Treatment Sample-duplicate	
WWK-D-BELPSDAT	4/23/2002	0.12		0.05	After Treatment Sample	
WWK-D-BELPSDAT	3/25/2002	0.109		0.05	After Treatment Sample	
WWK-D-BELPSDAT	2/7/2002	0.0786		0.05	After Treatment Sample	

Concentrations in ug/L

PFOA concentrations are rounded and reported to two significant figures. ND = Not Detected, NQ = Not Quantifiable, LOD = Limit of Detection, LOQ = Limit of Quantitation; ND < LOD < NQ < LOQ; The LOD/LOQ vary by instrument and quarter. RL = Reporting Limit. For samples collected prior to 10/1/13, limit of quantitation is reported. For samples collected after 10/1/13, reporting limit of 0.0050 for PFOA is reported. For samples collected after 10/1/16, reporting limit for PFOA is 0.010 ug/L.